

General data / project data / details and address

Building project/object/company

Part of the building / roof area

Address

Contact person

Date of next maintenance:	
Manufacturer: GRÜN GmbH • Siegener Str. 81-83 • D-57234 Wilnsdorf	
Product identification *	Quantity / Length

* Assembly documentation must be completed for each type of anchor device

Client	Assembly company	Responsible fitter
Company	Company	Name
Address	Address	Phone number
Address	Address	Date, signature

Checklist

CHECK POINTS: checked and OK!	= ☒	Comments:
Documentation:		
Assembly documentation	☐	
Maintenance documentation	☐	
Assembly instructions & safety instructions available	☐	
Roof scheme plan available	☐	
Marking / type plate / test date legible	☐	

Checklist

CHECK POINTS:	checked and OK!	=	☒	Comments:
Single anchor device / system supports:				
no deformation			☐	
no corrosion			☐	
Vibration test (tight fit)			☐	
Required load available in a safe position			☐	
Lock nuts: Thread protrusion min. 2 mm			☐	

Lifeline system GREENLINE

no deformation	☐	
no corrosion	☐	
tight fit of the cylinder head screws "cable clamp" (5Nm)	☐	
Indicator clamp (green) mounted and distance ≤ 2 mm	☐	
Rope pretension	☐	
Rope strand condition	☐	
Lock nuts: Thread protrusion min. 2 mm	☐	
Cable glider wear dimension (see separate instructions)	☐	

Acceptance result / summary:

- ☐ **Yes** The anchor device complies with the manufacturer's assembly instructions and the state of the art. The safety-related reliability is confirmed.

☐ **No** The following defects have been identified and must be rectified:
