

General data / project data / details and address

Building project/object/company	Date of next inspection:	
Part of the building / roof area	Manufacturer: GRÜN GmbH • Siegener Str. 81-83 • D-57234 Wilnsdorf	
Address	Product identification *	Quantity / Length
Contact person	* Inspection documentation must be completed for each type of anchor device	

Client	Assembly company	Responsible fitter
Company	Company	Name
Address	Address	Phone number
Address	Address	Date, signature

Checklist

CHECK POINTS:	checked and OK!	= ☒	Comments:
Documentation:			
Assembly documentation	☐		
Inspection documentation	☐		
Assembly instructions & safety instructions available	☐		
Roof scheme plan available	☐		
Marking / type plate / test date legible	☐		

Checklist

CHECK POINTS: checked and OK!	=	☒	Comments:
Single anchor device / system supports:			
no deformation		☐	
no corrosion		☐	
Vibration test (tight fit)		☐	
Required load available in a safe position		☐	
Lock nuts: Thread protrusion min. 2 mm		☐	

Lifeline system GREENLINE			
no deformation		☐	
no corrosion		☐	
tight fit of the cylinder head screws "cable clamp" (5Nm)		☐	
Indicator clamp (green) mounted and distance ≤ 2 mm		☐	
Rope pretension		☐	
Rope strand condition		☐	
Lock nuts: Thread protrusion min. 2 mm		☐	
Cable glider wear dimension (see separate instructions)		☐	

Acceptance result / summary:

- ☐ **Yes** The anchor device complies with the manufacturer's assembly instructions and the state of the art. The safety-related reliability is confirmed.
- ☐ **No** The following defects have been identified and must be rectified:
